

## ARCHITECTURAL SPECIFICATIONS PANASONIC ADVANCED VENTILATION SERIES



### **Ceiling Mounted Ventilation Fan/Heater**

**FV-11VH2 WhisperWarm** Ventilation fan and heat combination shall be ceiling mount, with no less than 110 CFM and no more than 0.6 sone as certified by the Home Ventilating Institute (HVI) at 0.1 static pressure in inches water gauge. Ventilating fan power consumption shall be no greater than 30.7 watts and efficiency rating of no less than 3.6 CFM/watt. The motor shall be totally enclosed, 4 pole condenser type engineered to run continuously. Power rating shall be 120v/60Hz. Duct diameter shall be no less than 4". Fan is not intended for installation over a tub/shower enclosure. Fan shall be California Title-24 compliant. Heating element shall be a Nichrome wire in a tubular steel sheath construction with magnesium oxide for optimal heat transfer. Heating element power consumption shall be no less than 1400 watts. Heating feature shall include an 90CFM blower fan with energy efficient condenser type motor with quick 1-minute warm-up.